

WARRANTY & REPAIR POLICY

Your **SENSIT®TKX** instrument is warranted to be free from defects in materials and workmanship for a period of one year after purchase (excluding sensor and batteries). If within the warranty period your instrument should become inoperative from such defects, the unit will be repaired or replaced at our option. This warranty covers normal use and does not cover damage which occurs in shipment or failure which results from alteration, tampering, accident, misuse, abuse, neglect, or improper maintenance. A purchase receipt or other proof of date of original purchase may be required before warranty performance will be rendered. Instruments out of warranty will be repaired for a service charge. Return the unit post-paid and insured to:

SENSIT TECHNOLOGIES

ATTN: Service Dept.
851 Transport Drive
Valparaiso, IN 46383

www.gasleaksensors.com

This warranty gives you specific legal rights and you may also have other rights which vary from state to state.

SENSIT®TKX

Combustible Gas Leak Detector INSTRUCTION MANUAL

Read and understand instructions before use.



7WA6

Approved UL913, For Class 1, Division 1, Groups C & D hazardous locations when used with alkaline batteries.



Warning:

To prevent ignition of flammable or combustible atmospheres, disconnect power before servicing.

For more information contact:

SENSIT TECHNOLOGIES

851 Transport Drive
Valparaiso, IN 46383
(888) 4-SENSIT (473-6748)
Phone: (219) 465-2700
Fax: (219) 465-2701
www.gasleaksensors.com

TTT Environmental & Safety
Instruments and Supplies

*The preferred source for instrument
rentals, sales, service and supplies!*

Anchorage (907) 770-9041 Seattle (253) 373-9041 Fairbanks (907) 374-9040

www.tttenviro.com

info@tttenviro.com



CONTENTS

1. Specifications
 2. Product Features
 2. Accessories and Parts
 3. General Description
 3. Safety Approval
 4. Operation
 5. Battery Replacement
 6. Operation Check
 6. Sensor Replacement
 7. Warranty and Repair Policy
-

CAUTION

This safety symbol is used to indicate a potentially hazardous situation which, if not avoided, may result in minor or moderate injury.

SPECIFICATIONS

Power Supply:	3 "C" Alkaline Batteries
Sensor:	Solid State
Sensitivity:	20 ppm Methane
Warm up:	Approx. 1 Minute
Response Time:	Instantaneous
Duty Cycle:	Continuous
Battery Life:	Approx. 30 Hours
Size:	3.5" x 10" x 1.6" (89 x 254 x 40 mm)
Weight:	1.3 lbs. (591 g)
Probe Length:	16"
Approvals:	UL913 Intrinsically Safe

OPERATION CHECK

First follow steps 1, 2 and 3 (page 4) in the Operations section. Then expose the sensor to a known gas source such as an unlit butane lighter. The tick should increase when the gas is applied. The tick will decrease when the gas is removed.

If the unit fails to respond, the sensor may need replacing or the unit may need to be sent in for repair (see below).

 **CAUTION:** This instrument must be only repaired by a factory authorized repair technician.

SENSOR REPLACEMENT

1. Turn the unit off
2. Pull off the sensor cap
3. Unplug the old sensor and discard
4. Line up reference tab on side of sensor with reference mark (\square) on sensor circuit board and plug in sensor
5. Replace sensor cap
6. Turn on unit and perform "Operation Check"

5. When this instrument is used in noisy environments, look at the red leak indicator LED that flashes more rapidly as the tick rate increases. You can also use the supplied earphone.

6. If the green LED does not illuminate or blinks, the batteries must be replaced.

7. If the instrument does not perform or it has been damaged, test the instrument by following the “operation check” procedure in this manual.

BATTERY REPLACEMENT

If the green LED fails to illuminate, the batteries need replacement. Depress the latch using a coin and slide the battery compartment cover off. Replace the batteries with 3 “C” alkaline batteries.

When replacing the batteries observe the polarity markings on the sides of the battery compartment. A fresh set of alkaline batteries should operate the unit for approximately 30 hours.



SENSIT® TKX

ACCESSORIES and PARTS

STANDARD ACCESSORIES (INCLUDED)

Carrying Pouch	360-00002
Instruction Manual	750-00043
Alkaline Batteries	310-00004

OPTIONAL ACCESSORIES/PARTS

Sensor	375-2611-01
--------	-------------

GENERAL DESCRIPTION

The **SENSIT®TKX** instrument is an advanced state-of-the-art leak detector capable of detecting many combustible, non-combustible and toxic gases.

The **SENSIT®TKX** solid state sensor is sensitive to most combustible and/or toxic gases.

A partial list of these gases is:

Acetone, Alcohol, Ammonia, Steam, Butane, Gasoline, Jet Fuel, Hydrogen Sulfide, smoke, Industrial Solvents, Methane, Lacquer Thinner, Naphtha, Propane, Natural Gas.

CAUTION

This instrument is not to be used as a carbon monoxide investigative tool or to quantify any gas concentration.

SAFETY APPROVAL

SENSIT®TKX is approved by Underwriters Laboratories to UL913, for Class I, Division 1, Groups C & D hazardous locations when used with *Duracell™* MN1400K or equivalent alkaline batteries.

OPERATIONS

1. Turn the unit on in an uncontaminated environment by moving the switch from the “OFF” to the “ON” position.
2. The green ready LED will illuminate if there is ample battery power. The red LED may flicker and the tick may sound during the warm up. To silence the tick, rotate the tick wheel fully counterclockwise.
3. Adjust the “TICK ADJUST” by rotating it in a clockwise direction until a uniform tick begins to sound. A uniform tick rate indicates a fully warmed up instrument. The red LED will flash at the same time the tick sounds.
4. Approach suspected leak areas with the sensor until the tick begins to increase. When the tick increases do not move the sensor from the suspected leak area, rotate the tick adjust slightly counterclockwise to slow the ticking sound and continue to approach the leak. Continue to use this method to pinpoint the leak.

REMEMBER: An increase in tick indicates you are approaching a leak, a decrease in tick indicates you are moving away.

(Operations continued on page 5)